LAB REPORT

Unit ID Autoclave

Component Heat transfer oil

Lab number 1700707





page 1 of 1

OELCHECK GmbH · Kerschelweg 28 · 83098 Brannenburg

Example report

Analysis scope: Analysis-Kit 3

Machine type: Thermalölanlage
Manufacturer: AEU

Oil brand name: Mobiltherm 603

Oil quantity in system: 250 I

Diagnosis for the current laboratory values

No wear metals present in the sample. AN (neutralization number) higher than expected but not yet critical. Possible reason: oxidation or oil aging. The flash point is lower than the flash point of the fresh oil. Probable cause: high operating temperatures, which cause the formation of volatile crack products. Please observe further changes with the next sample. Please send us another sample on the occasion of your next inspection, but no later than six months from now.

Dipl.-Ing. Stefan Mitterer

Sample Rating



Caution

ANALYSIS RESULT	S		Current sample	F	Previous sample
LAB NUMBER			1700707		
SAMPLE RATING			i)		
Date tested			09.06.2023		
Date tested Date of sample taken			04.06.2023		
Date of last oil change			12.02.2023		
Top-up since change			0		
Operating time since change h		2360			
Total operating time h		26690			
Oil changed		no			
			110		
WEAR Iron	Fe	mg/kg	0		
Chrome	Cr	mg/kg mg/kg	0		
Tin	Sn	mg/kg	0		
Aluminum	Al	mg/kg	0		
Nickel	Ni	mg/kg	0		
Copper	Cu	mg/kg	0		
Lead	Pb	mg/kg	0		
Molybdenum	Мо	mg/kg	0		
PQ index	-	mg/ng	< 25		
CONTAMINATION					
Silicon	Si	mg/kg	0		
Potassium	K	mg/kg	0		
Sodium	Na	mg/kg	1		
Water	%		< 0.10		
OIL CONDITION				 	
Viscosity at 40°C	mm²/s		22.12		
Viscosity at 100°C	mm²/s		4.36		
Viscosity index	-		104		
Oxidation	A/cm		6		
IR index	-		99.54		
ADDITIVES					
Calcium	Ca	mg/kg	4		
Magnesium	Mg	mg/kg	0		
Boron	В	mg/kg	0		
Zinc	Zn	mg/kg	6		
Phosphorus	Р	mg/kg	4		
Barium	Ва	mg/kg	0		
Sulphur	S	mg/kg	5551		
ADDITIONAL TESTS				 	
AN / NN	mgKOH/g		0.49		
Flash point closed	SSCC	°C	161	 	





100 900 900 900 900 900 1000 1000

Infrared Spectrum