Unit ID

Steam turbine

Component

Lubricating oil 10T

Current sample number

1702851

OELCHECK GmbH · Kerschelweg 28 · 83098 Brannenburg

Example report Analysis scope: Turbine Oil Kit 10 Machine type: Manufacturer: Sample from: Oil brand name: Oil quantity in system:

EG49/8/8 Siemens/Bergmann Borsig Lubricating oil Aral Kosmol TF 46 3000 I

Diagnosis for the current laboratory values

No wear metals present in the sample. The oil cleanliness is within the expected limits. The foaming tendency has increased slightly. The air release property has increased slightly. Please observe further changes with the next sample. I recommend that you send the next sample at the next service interval or at your regular inspection for trend analysis. Dipl.-Ing. (FH) Stefan Mitterer



Sample Rating

Caution

| ANALYSIS RESUL | TS | | Current sample | Previous samples |
|-------------------------|----------|-------|----------------|------------------|
| LAB NUMBER | | | 1702851 | |
| SAMPLE RATING | | | () | |
| Date tested | | | 11.05.2023 | |
| Date of sample taken | | | 02.05.2023 | |
| Date of last oil change | | | 01.09.2015 | |
| Top-up since change | | | - | |
| Operating time since of | change | h | 59805 | |
| Total operating time | , | h | 351596 | |
| Oil changed | | | no | |
| WEAR | | | | |
| Iron | Fe | mg/kg | 0 | |
| Chrome | Cr | mg/kg | 0 | |
| Tin | Sn | mg/kg | 0 | |
| Aluminum | AI | mg/kg | 0 | |
| Nickel | Ni | mg/kg | 0 | |
| Copper | Cu | mg/kg | 0 | |
| Lead | Pb | mg/kg | 0 | |
| Molybdenum | Мо | mg/kg | 0 | |
| PQ index | - | 00 | < 25 | |
| CONTAMINATION | | | | |
| Silicon | Si | mg/kg | 0 | |
| Potassium | к | mg/kg | 1 | |
| Sodium | Na | mg/kg | 0 | |
| Lithium | Li | mg/kg | 0 | |
| Water K. F. | ppm | | 97 | |
| OIL CONDITION | | | | |
| Viscosity at 40°C | mm²/s | | 44.96 | |
| Viscosity at 100°C | mm²/s | | 6.80 | |
| Viscosity index | - | | 106 | |
| Oxidation | A/cm | | 1 | |
| IR index | - | | 99.76 | |
| Color | Color in | dex | 1.5 | |
| ADDITIVES | | | | |
| Calcium | Ca | mg/kg | 0 | |
| Magnesium | Mg | mg/kg | 0 | |
| Boron | В | mg/kg | 0 | |
| Zinc | Zn | mg/kg | 0 | |
| Phosphorus | Р | mg/kg | 12 | |
| Barium | Ва | mg/kg | 0 | |
| Sulphur | S | mg/kg | 236 | |



Scan QR code

Send new sample





page 1 of 4

Unit ID

Component

Steam turbine

Lubricating oil 10T

Current sample number

1702851






page 2 of 4

Machine type: Manufacturer: Sample from: Oil brand name: Oil quantity in system: EG49/8/8 Siemens/Bergmann Borsig Lubricating oil Aral Kosmol TF 46 3000 I

Example report Analysis scope: Turbine Oil Kit 10

| ANALYSIS RESULTS | 5 | Current sample |
|---------------------------|-----------------|----------------|
| LAB NUMBER | | 1702851 |
| SAMPLE RATING | | i |
| Date tested | | 11.05.2023 |
| Date of sample taken | | 02.05.2023 |
| Date of last oil change | | 01.09.2015 |
| Top-up since change | | - |
| Operating time since char | nge h | 59805 |
| Total operating time | h | 351596 |
| Oil changed | | no |
| ADDITIONAL TESTS | | |
| AN / NN | mgKOH/g | 0.13 |
| MPC | | 8.30 |
| Air-release properties | min | 6.3 |
| Water separation (steam) | S | 111 |
| Foam test seq. I | ml/ml | 500/0 |
| Cleanliness class | ISO 4406 | 17/15/11 |
| A: >4µm = ISO >4µm | Particles/100ml | 121520 |
| B: >6µm = ISO >6µm | Particles/100ml | 23180 |
| C: >14µm = ISO >14µm | Particles/100ml | 1910 |
| D: >21µm | Particles/100ml | 790 |
| E: >38µm | Particles/100ml | 130 |
| F: >70µm | Particles/100ml | 40 |
| Cleanliness class | SAE AS 4059 | 8A |
| Steel corrosion | DIN ISO 7120/A | pass |
| Antioxidant 1 - RULER | % | 87.3 |
| Antioxidant 2 - RULER | % | 49.9 |



1702851

Unit ID

Component

Steam turbine

Lubricating oil 10T

Current sample number

Example report




page 3 of 4

Machine type: Manufacturer: Sample from: Oil brand name: Oil quantity in system: EG49/8/8 Siemens/Bergmann Borsig Lubricating oil Aral Kosmol TF 46 3000 I


Evaluation of the oxidation inhibitors


Analysis scope: Turbine Oil Kit 10

Compared to the reference sample, only a slight degradation of antioxidants is visible. There is still enough aging protection in the oil. **Dipl.-Ing. (FH) Stefan Mitterer**



| ANALYSIS RESULTS | | | | | |
|------------------|------------|--|--|--|--|
| | 1702851 | | | | |
| | 11.05.2023 | | | | |
| | 02.05.2023 | | | | |
| | 01.09.2015 | | | | |
| | - | | | | |
| h | 59805 | | | | |
| h | 351596 | | | | |
| | no | | | | |
| | | | | | |
| | | | | | |
| % | 87,3 | | | | |
| % | 49,9 | | | | |
| | h % | | | | |





Scan QR code Send new sample



Unit ID

Component

Steam turbine

1702851

Lubricating oil 10T

Current sample number

Example report




page 4 of 4

Machine type: Manufacturer: Sample from: Oil brand name: Oil quantity in system: EG49/8/8 Siemens/Bergmann Borsig Lubricating oil Aral Kosmol TF 46 3000 I

Analysis scope: Turbine Oil Kit 10

Diagnosis of the MPC test

The MPC value is within a normal range. There is no risk for the formation of varnish. **Dipl.-Ing. (FH) Stefan Mitterer**



| ANALYSIS RESULTS | Current sample | |
|-----------------------------|----------------|------------|
| LAB NUMBER | | 1702851 |
| Date tested | | 11.05.2023 |
| Date of sample taken | | 02.05.2023 |
| Date of last oil change | | 01.09.2015 |
| Top-up since change | | - |
| Operating time since change | h | 59805 |
| Total operating time | h | 351596 |
| Oil changed | | no |

MPC test

| MPC | 8,30 |
|--------------------|-------|
| Luminance L | 97,80 |
| Redness index a | 0,10 |
| Yellowness index b | 5,80 |

MPC test membrane



